

Annual Drinking Water Quality Report

MacBee SUD Jackson

Public Water System TX 2340045

We are pleased to present to you the Annual Water Quality Report (Consumer Confidence Report) for the year of January 1 to December 31, 2025. This report is intended to provide you with important information about your drinking water and the efforts made by the water system to provide safe drinking water (Este reporte incluye información importante sobre el agua para tomar. Para asistencia en español, favor de llamar al telefono (903) 873-2109.

For more information regarding this report, please contact Tim Smith, Interim General Manager. The office phone number is 903-873-2109, or visit our website at www.macbeewater.com

Sources of Drinking Water

MACBEE SUD JACKSON is Ground water.

Our water source(s) and source water assessment information are listed below:

Source Name	Location	Type of Water	Report Status	Location
1- CR 2211	VZCR 2211	Ground Water	Yes	www.macbeewater.com
2- REMOTE/S of WELL #1	REMOTE /S OF WELL #1	Ground Water	Yes	www.macbeewater.com
3 -S of FM 1651/HWY 198	S OF FM 1651/HWY 198	Ground Water	Yes	www.macbeewater.com

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPAs Safe Drinking Water Hotline at (800) 426-4791.

Contaminants that may be present in source water include:

- Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- Inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-

products of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff, and septic systems.

- Radioactive contaminants, which can be naturally occurring or the result of oil and gas production and mining activities

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Some people may be more vulnerable to contaminants in drinking water than the general population.

Contaminants may be found in drinking water that may cause taste, color, or odor problems. These types of problems are not necessarily causes for health concerns. For more information on taste, odor, or color of drinking water, please contact the system's business office.

Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CD guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

Lead can cause serious health effects in people of all ages, especially pregnant people, infants (both formula-fed and breastfed), and young children. Lead in drinking water is primarily from materials and parts used in service lines and in home plumbing. MACBEE SUD JACKSON is responsible for providing high quality drinking water and removing lead pipe, but cannot control the variety of materials used in the plumbing in your home. Because lead levels may vary over time, lead exposure is possible even when your tap sampling results do not detect lead at one point in time. You can help protect yourself and your family by identifying and removing lead materials within your home plumbing and taking steps to reduce your family's risk. Using a filter, certified by an American National Standards Institute accredited certifier to reduce lead, is effective in reducing lead exposures. Follow the instructions provided with the filter to ensure the filter is used properly. Use only cold water for drinking, cooking, and making baby formula. Boiling water does not remove lead from water. Before using tap water for drinking, cooking, or making baby formula, flush your pipes for several minutes. You can do this by running your tap, taking a shower, doing laundry or a load of dishes. If you have a lead service line or galvanized requiring replacement service line, you may need to flush your pipes for a longer period. If you are concerned about lead in your water and wish to have your water tested, contact MACBEE SUD JACKSON at 903-873-2179. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available at <https://www.epa.gov/safewater/lead>.

A service line inventory has been prepared and can be accessed at our website at www.macbeewater.com, under the [Important Notice Tab](#) or [https://clients.ruralwaterimpact.com/documents/1425/TX_2340045-JACKSON- d Service Inventory 2025.pdf](https://clients.ruralwaterimpact.com/documents/1425/TX_2340045-JACKSON-d_Service_Inventory_2025.pdf)

In the tables below, you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms, we've provided the following definitions:

Action Level (AL): The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Action Level Goal (ALG): The level of a contaminant in drinking water below which there is no known or expected risk to health. ALGs allow for a margin of safety.

Level 1 Assessment: A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.

Level 2 Assessment: A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an E. coli MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.

Maximum Contaminant Level or MCL: The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal or MCLG: The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum residual disinfectant level goal or MRDLG: The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Maximum residual disinfectant level or MRDL: The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Treatment Technique or TT: A required process intended to reduce the level of a contaminant in drinking water.

Variances and Exemptions: State or EPA permission not to meet an MCL or a treatment technique under certain conditions.

Avg: Average - Regulatory compliance with some MCLs are based on running annual average of monthly samples.

RAA: Running Annual Average.

LRAA: Locational Running Annual Average.

mrem: millirems per year (a measure of radiation absorbed by the body).

ppb: micrograms per liter (ug/L) or parts per billion - or one ounce in 7,350,000 gallons of water.

ppm: milligrams per liter (mg/L) or parts per million - or one ounce in 7,350 gallons of water.

picocuries per liter (pCi/L): picocuries per liter is a measure of the radioactivity in water.

na: not applicable.

Disinfectant Residual

All public water systems in Texas are required to disinfect drinking water to ensure control of microbial contaminants. Disinfectants are water additives used to control microbes.

Disinfectant	YEAR	AVERAGE LEVELS	UNITS	RANGE	MDL/MRDLG GOAL
Chlorine (Free)	2025	2.69	Mg/l	0.0-4.0	4/4

Regulated Contaminants

In the tables below, we have shown the regulated contaminants that were detected. Chemical Sampling of our drinking water may not be required on an annual basis; therefore, information provided in this table refers back to the latest year of chemical sampling results.

Lead and Copper	Period	90TH Percentile: 90% of your water utility levels were less than	Range of Sampled Results (low - high)	Unit	AL	Sites Over AL	Typical Source
COPPER, FREE	2023 - 2025	0.202	0 - 0.354	ppm	1.3	0	Corrosion of household plumbing systems; Erosion of natural deposits; Leaching from wood preservatives
LEAD	2023 - 2025	0	0	ppb	15	0	Corrosion of household plumbing systems; Erosion of natural deposits

Disinfection Byproducts	Sample Point	Period	Highest LRAA	Range	Unit	MCL	MCLG	Typical Source
TOTAL HALOACETIC ACIDS	SMP STA: 1651	2024	11	10.5	ppb	60	0	By-product of drinking water

(HAA5)	HWY 198, CANTON, TX							disinfection
TTHM	SMP STA: 1651 HWY 198, CANTON, TX	2024	41	40.9	ppb	80	0	By-product of drinking water chlorination
Regulated Contaminants	Collection Date	Highest Value	Range	Unit	MCL	MCLG	Typical Source	
BARIUM	7/28/2025	0.036	0.036	ppm	2	2	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits	
DIBROMOCHLOROMETHA NE	6/26/2024	18.1	14.7 - 18.1	UG/L	0	0.06		
FLUORIDE	6/26/2024	0.211	0.211	ppm	4	4	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories	
NITRATE	7/28/2025	0.0419	0.0419	ppm	10	10	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits	

There are no additional required health effects notices.

There are no additional required health effects violation notices.

Ground Water Sources						
Source Id	Drill Date	Top Screened Interval (Ft.)	Bottom Screened Interval (Ft.)	Pumpage Rate (GPM)	Entry Point	Operational Status
G2340045A		349	482	72	001	Operational
G2340045B		382	422	60	001	Operational

PWS System Susceptibility Summary: Contaminants with HIGH Susceptibility

The system is rated as having HIGH susceptibility to the contaminants listed below.

D.W. CONTAM. CANDIDATE LIST

Contaminant Name	Structural Integrity	Aquifer/Watershed Properties	Nonpoint Source	Point Source	Area Primary Influence	Contaminant Occurrence	Summary
1,3-DICHLOROPROPENE	----	Moderate	High	----	----	----	High
2,4-DICHLOROPHENOL	----	Moderate	High	----	----	----	High
2,4-DINITROPHENOL	----	Moderate	High	----	----	----	High
ACETOCHLOR	----	Moderate	High	----	----	----	High
LINURON	----	Moderate	High	----	----	----	High
MOLINATE	----	Moderate	High	----	----	----	High
BORON	----	Moderate	High	----	----	----	High
PROPAZINE	----	Moderate	High	----	----	----	High
TERBACIL	----	Moderate	High	----	----	----	High
TERBUFOS	----	Moderate	High	----	----	----	High
CYANAZINE	----	Moderate	High	----	----	----	High
DCPA DI-ACID DEGRADATE	----	Moderate	High	----	----	----	High
DCPA MONO-ACID DEGRADATE	----	Moderate	High	----	----	----	High
DDE	----	Moderate	High	----	----	----	High
DIAZINON	----	Moderate	High	----	----	High	High
DISULFOTON	----	Moderate	High	----	----	----	High
DIURON	----	Moderate	High	----	----	----	High
EPTC	----	Moderate	High	----	----	----	High
FONOFOS	----	Moderate	High	----	----	----	High

INORGANICS

Contaminant	Structural	Aquifer/Watershed	Nonpoint	Point	Area	Contaminant
Name	Integrity	Properties	Source	Source	Primary Influence	Occurrence
MANGANESE	----	Moderate	High	----	----	----
Summary						
						High
ALUMINUM	----	Moderate	Moderate	----	----	High
TDS	----	Moderate	High	----	----	High
ZINC	----	Moderate	Moderate	----	----	High
CHLORIDE	----	Moderate	Low	----	----	High

High

INORGANICS MONITORED

Contaminant Name

Structural Integrity	Aquifer/Watershed Properties	Nonpoint Source	Point Source	Area Primary Influence	Contaminant Occurrence	Summary
----	Moderate	----	----	----	High	High
----	Moderate	High	----	----	----	High
MAGNESIUM						
SPECIFIC CONDUCTANCE						

INORGANICS UNREGULATED

Summary
High High

Name	Contaminant	Structural Integrity	Aquifer/Watershed Properties	Nonpoint Source	Point Source	Area Primary Influence	Contaminant Occurrence
	CALCIUM	----	Moderate	----	----	----	High
	SODIUM	----	Moderate	High	----	----	High

PHYSICAL

Summary
High

Contaminant	Structural	Aquifer/Watershed	Nonpoint	Point	Area	Contaminant
Name	Integrity	Properties	Source	Source	Primary Influence	Occurrence
HARDNESS	----	Moderate	High	----	----	----

SOC MONITORED

Contaminant Name	Structural Integrity	Aquifer/Watershed Properties	Nonpoint Source	Point Source	Area Primary Influence	Contaminant Occurrence	Summ
2,4,5-T	----	Moderate	High	----	----	----	Hig
3-HYDROXYCARBOFURAN	----	Moderate	High	----	----	----	High
ACENAPHTHENE	----	Moderate	High	----	----	----	High
METHIOCARB	----	Moderate	High	----	----	----	High
METHOMYL	----	Moderate	High	----	----	----	High
METOLACHLOR	----	Moderate	High	----	----	----	High
METRIBUZIN	----	Moderate	High	----	----	----	High
ALDRIN	----	Moderate	High	----	----	----	High
ANTHRACENE	----	Moderate	High	----	----	----	High
BENTAZON	----	Moderate	High	----	----	----	High
BROMACIL	----	Moderate	High	----	----	----	High
BUTACHLOR	----	Moderate	High	----	----	----	High
CARBARYL	----	Moderate	High	----	----	----	High
PROMETON	----	Moderate	High	----	----	----	High
PROPACHLOR	----	Moderate	High	----	----	----	High

TRIFLURALIN	----	Moderate	High	----	----	----	High
CHRYSENE	----	Moderate	High	----	----	----	High
DICAMBA	----	Moderate	High	----	----	----	High
DIELDRIN	----	Moderate	High	----	----	----	High
DIETHYL PHTHALATE	----	Moderate	High	----	----	----	High
DIMETHYL PHTHALATE	----	Moderate	High	----	----	----	High
LAMBAST	----	Moderate	High	----	----	----	High

SOC REGULATED

Contaminant Name	Structural Integrity	Aquifer/Watershed Properties	Nonpoint Source	Point Source	Area Primary Influence	Contaminant Occurrence	Summary
2,4,5-TP	----	Moderate	High	----	----	----	High
2,4-D	----	Moderate	High	----	----	----	High
ALACHLOR	----	Moderate	High	----	----	----	High
ALDICARB	----	Moderate	High	----	----	----	High
LINDANE	----	Moderate	High	----	----	----	High
METHOXYCHLOR	----	Moderate	High	----	----	----	High
ALDICARB SULFOXIDE	----	Moderate	High	----	----	----	High
ATRAZINE	----	Moderate	High	----	----	----	High
CARBOFURAN	----	Moderate	High	----	----	----	High
ALDICARB SULFONE	----	Moderate	High	----	----	----	High
OXAMYL	----	Moderate	High	----	----	----	High
PICLORAM	----	Moderate	High	----	----	----	High
SIMAZINE	----	Moderate	High	----	----	----	High
TOXAPHENE	----	Moderate	High	----	----	----	High
CHLORDANE	----	Moderate	High	----	----	----	High
CHLORDANE (ALPHA-CHLORDANE)	----	Moderate	High	----	----	----	High
CHLORDANE (GAMMA-CHLORDANE)	----	Moderate	High	----	----	----	High
CHLORDANE (TRANS-NONACHLOR)	----	Moderate	High	----	----	----	High
DALAPON	----	Moderate	High	----	----	----	High
DI-(2-ETHYLHEXYL)ADIPATE	----	Moderate	High	----	----	----	High
DI-(2-ETHYLHEXYL)PHTHALATE	----	Moderate	High	----	----	----	High
DIBROMOCHLOROPROPANE	----	Moderate	High	----	----	----	High
DINOSEB	----	Moderate	High	----	----	----	High
DIQUAT	----	Moderate	High	----	----	----	High
ENDOTHALL	----	Moderate	High	----	----	----	High
ENDRIN	----	Moderate	High	----	----	----	High
GLYPHOSATE	----	Moderate	High	----	----	----	High
HEPTACHLOR	----	Moderate	High	----	----	----	High
HEPTACHLOR EPOXIDE	----	Moderate	High	----	----	----	High
HEXACHLOROBENZENE	----	Moderate	High	----	----	----	High
HEXACHLOROCYCLOPENTADIENE	----	Moderate	High	----	----	----	High
Contaminant Name	Structural Integrity	Aquifer/Watershed Properties	Nonpoint Source	Point Source	Area Primary Influence	Contaminant Occurrence	Su
2,4,5-TP	----	Moderate	High	----	----	----	
2,4-D	----	Moderate	High	----	----	----	
ALACHLOR	----	Moderate	High	----	----	----	
ALDICARB	----	Moderate	High	----	----	----	
LINDANE	----	Moderate	High	----	----	----	
METHOXYCHLOR	----	Moderate	High	----	----	----	
ALDICARB SULFOXIDE	----	Moderate	High	----	----	----	
ATRAZINE	----	Moderate	High	----	----	----	
CARBOFURAN	----	Moderate	High	----	----	----	
ALDICARB SULFONE	----	Moderate	High	----	----	----	
OXAMYL	----	Moderate	High	----	----	----	
PICLORAM	----	Moderate	High	----	----	----	
SIMAZINE	----	Moderate	High	----	----	----	
TOXAPHENE	----	Moderate	High	----	----	----	
CHLORDANE	----	Moderate	High	----	----	----	

CHLORDANE (ALPHA-CHLORDANE) CHLORDANE (GAMMA-CHLORDANE) CHLORDANE (TRANS-NONACHLOR)	CHLORDANE (ALPHA-CHLORDANE)	----	Moderate	High	----	----	----
	CHLORDANE (GAMMA-CHLORDANE)	----	Moderate	High	----	----	----
	CHLORDANE (TRANS-NONACHLOR)	----	Moderate	High	----	----	----
THM	DALAPON	----	Moderate	High	----	----	----
	DI-(2-ETHYLHEXYL)ADIPATE	----	Moderate	High	----	----	----
	DI-(2-ETHYLHEXYL)PHthalate	----	Moderate	High	----	----	----
	DIBROMOCHLOROPROPANE	----	Moderate	High	----	----	----
	DINOSEB	----	Moderate	High	----	----	----
	DIQUAT	----	Moderate	High	----	----	----
	ENDOTHALL	----	Moderate	High	----	----	----
	ENDRIN	----	Moderate	High	----	----	----
	GLYPHOSATE	----	Moderate	High	----	----	----
	HEPTACHLOR	----	Moderate	High	----	----	----
	HEPTACHLOR EPOXIDE	----	Moderate	High	----	----	----
	HEXACHLORO BENZENE	----	Moderate	High	----	----	----
	HEXACHLOROCYCLOPENTADIENE	----	Moderate	High	----	----	----

Summary
High High

Name	Contaminant	Structural Integrity	Aquifer/Watershed Properties	Nonpoint Source	Point Source	Area Primary Influence	Contaminant Occurrence
	BROMOMETHANE	----	Moderate	High	----	----	----
	CHLOROFORM	----	Moderate	High	----	----	----

VOC - OTHER COMPOUNDS

Contaminant Name	Structural Integrity	Aquifer/Watershed Properties	Nonpoint Source	Point Source	Area Primary Influence	Contaminant Occurrence	Su
	----	Moderate	High	----	----	----	
	----	Moderate	High	----	----	----	
CARBON DISULFIDE							
METHYL IODIDE (Iodomethane)							

VOC MONITORED

Contaminant Name	Structural Integrity	Aquifer/Watershed Properties	Nonpoint Source	Point Source	Area Primary Influence	Contaminant Occurrence	Su
1,1,2,2-TETRACHLOROETHANE	----	Moderate	High	----	----	----	
1,3-DICHLOROPROPANE	----	Moderate	High	----	----	----	
2-CHLOROTOLUENE	----	Moderate	High	----	----	----	
TRANS-1,3-DICHLOROPROPENE	----	Moderate	High	----	----	----	
TRICHLOROFLUOROMETHANE	----	Moderate	High	----	----	----	
CHLOROETHANE	----	Moderate	High	----	----	----	
CIS-1,3-DICHLOROPROPENE	----	Moderate	High	----	----	----	
DICHLORODIFLUOROMETHANE	----	Moderate	High	----	----	----	

VOC REGULATED

Contaminant Name	Structural Integrity	Aquifer/Watershed Properties	Nonpoint Source	Point Source	Area Primary Influence	Contaminant Occurrence	Su
1,1,1-TRICHLOROETHANE	----	Moderate	High	----	----	----	
1,1,2-TRICHLOROETHANE	----	Moderate	High	----	----	----	
1,1-DICHLOROETHYLENE	----	Moderate	High	----	----	----	
1,2,4-TRICHLOROBENZENE	----	Moderate	High	----	----	----	
1,2-DICHLOROETHANE	----	Moderate	High	----	----	----	
1,2-DICHLOROPROPANE	----	Moderate	High	----	----	----	

ORTHO-1,2-DICHLOROBENZENE	----		Moderate	High	----	-----	-----
PARA-1,4-DICHLOROBENZENE	----		Moderate	High	----	-----	-----
TETRACHLOROETHYLENE	----		Moderate	High	----	-----	-----
TOLUENE	-----		Moderate	High	----	-----	-----
TRICHLOROETHYLENE	----		Moderate	High	----	-----	-----
XYLENES (TOTAL)	-----		Moderate	High	----	-----	-----
CARBON TETRACHLORIDE	----		Moderate	High	----	-----	-----
CHLOROBENZENE (MONOCHLOROBENZENE)	----	Moderate	High	----	----	-----	High
ETHYLBENZENE	----	Moderate	High	----	----	-----	High
Other							
PWS System Susceptibility Summary: Contaminants with MODERATE Susceptibility							High High
The system is rated as having MODERATE susceptibility to the contaminants listed below.							

Contaminant Name	Structural Integrity	Aquifer/Watershed Properties	Nonpoint Source	Point Source	Area Primary Influence	Contaminant Occurrence
AROCOR (PCB)	----	Moderate	High	-----	-----	-----
TRIAZINES	----	Moderate	High	-----	-----	-----

D.W. CONTAM. CANDIDATE LIST						
Contaminant Name	Structural Integrity	Aquifer/Watershed Properties	Nonpoint Source	Point Source	Area Primary Influence	Contaminant Occurrence
1,2-DIPHENYLHYDRAZINE	-----	Moderate		-----	-----	
2,4,6-TRICHLOROPHENOL	-----	Moderate		-----	-----	
2,4-DINITROTOLUENE	-----	Moderate		-----	-----	
2,6-DINITROTOLUENE	-----	Moderate		-----	-----	
2-METHYLPHENOL	-----	Moderate		-----	-----	
NITROBENZENE	-----	Moderate		-----	-----	
ORGANOTINS	-----	Moderate		-----	-----	
PERCHLORATE	-----	Moderate		-----	-----	
RDX	-----	Moderate		-----	-----	

INORGANICS						
Contaminant Name	Structural Integrity	Aquifer/Watershed Properties	Nonpoint Source	Point Source	Area Primary Influence	Contaminant Occurrence
MERCURY	----	Moderate	Moderate	-----	-----	-----
NICKEL	----	Moderate	Moderate	-----	-----	-----
NITRATE	----	Moderate	Low	-----	-----	-----
NITRATE+NITRITE	----	Moderate	Low	-----	-----	-----
NITRITE	----	Moderate	Low	-----	-----	-----
ANTIMONY	----	Moderate	Moderate	-----	-----	-----
ARSENIC	----	Moderate	----	-----	-----	-----
ASBESTOS	----	Moderate	----	-----	-----	-----
BARIUM	----	Moderate	----	-----	-----	-----
BERYLLIUM	----	Moderate	Moderate	-----	-----	-----
BROMIDE	----	Moderate	----	-----	-----	-----
CADMIUM	----	Moderate	----	-----	-----	-----
SELENIUM	-----	Moderate	-----	-----	-----	Moderate
SILVER	----	Moderate	-----	-----	-----	
SULFATE	----	Moderate	Low	-----	-----	
THALLIUM CHROMIUM	-----	Moderate Moderate	-----	-----	-----	
COPPER CYANIDE	-----	Moderate Moderate	Low Moderate	-----	-----	
FLUORIDE DROGEN	-----	Moderate Moderate	-----	-----	-----	
SULFIDE	-----		-----	-----	-----	
IRON	----	Moderate	Low	-----	-----	
HYDROGEN SULFIDE	-----	Moderate	Low	-----	-----	Moderate

INORGANICS MONITORED						
Contaminant Name	Structural Integrity	Aquifer/Watershed Properties	Nonpoint Source	Point Source	Area Primary Influence	Contaminant Occurrence

ALKALINITY	----	Moderate	----	----	----	----
BICARBONATE	----	Moderate	----	----	----	----
CARBONATE	----	Moderate	----	----	----	----
PHYSICAL PARAMETER						Summary
RADIOCHEM UNREGULATED			Moderate			

Contaminant Name	Structural Integrity	Aquifer/Watershed Properties	Nonpoint Source	Point Source	Area Primary Influence	Contaminant Occurrence
pH	-----	Moderate	Moderate	-----	-----	-----

RADIOCHEM

Contaminant Name	Structural Integrity	Aquifer/Watershed Properties	Nonpoint Source	Point Source	Area Primary Influence	Contaminant Occurrence	Summary
RADIUM-226	-----	Moderate	-----	-----	-----	-----	Moderate
RADIUM-228	----	Moderate	-----	-----	-----	-----	Mode
STRONTIUM-90	----	Moderate	-----	-----	-----	-----	Mode
TRITIUM	-----	Moderate	-----	-----	-----	-----	Mode
GROSS ALPHA	-----	Moderate	-----	-----	-----	-----	Mode
GROSS BETA	-----	Moderate	-----	-----	-----	-----	Mode
Contaminant Name	Structural Integrity	Aquifer/Watershed Properties	Nonpoint Source	Point Source	Area Primary Influence	Contaminant Occurrence	Summary
RADON	----	Moderate	-----	-----	-----	-----	Mode
STRONTIUM-89	----	Moderate	-----	-----	-----	-----	Mode
URANIUM	-----	Moderate	-----	-----	-----	-----	Mode

SOC MONITORED

Contaminant Name	Structural Integrity	Aquifer/Watershed Properties	Nonpoint Source	Point Source	Area Primary Influence	Contaminant Occurrence	Summary
ACENAPHTHYLENE	-----	Moderate	-----	-----	-----	-----	Mode
BENZO[A]ANTHRACENE	-----	Moderate	-----	-----	-----	-----	Mode
BENZO[B]FLUORANTHENE	-----	Moderate	-----	-----	-----	-----	Mode
BENZO[G,H,I]PERYLENE	-----	Moderate	-----	-----	-----	-----	Mode
BENZO[K]FLUORANTHENE	-----	Moderate	-----	-----	-----	-----	Mode
BUTYL BENZYL PHTHALATE	-----	Moderate	-----	-----	-----	-----	Mode
PHENANTHRENE	-----	Moderate	-----	-----	-----	-----	Mode
PYRENE	-----	Moderate	-----	-----	-----	-----	Mode
DIBENZ[A,H]ANTHRACENE	-----	Moderate	-----	-----	-----	-----	Mode
DI-N-BUTYL PHTHALATE	-----	Moderate	-----	-----	-----	-----	Mode
FLUORENE	-----	Moderate	-----	-----	-----	-----	Mode
INDENO[1,2,3,CD]PYRENE	-----	Moderate	-----	-----	-----	-----	Mode

SOC REGULATED

Contaminant Name	Structural Integrity	Aquifer/Watershed Properties	Nonpoint Source	Point Source	Area Primary Influence	Contaminant Occurrence	Summary
2,3,7,8-TCDD	-----	Moderate	-----	-----	-----	-----	Mode
BENZO(A)PYRENE	-----	Moderate	Moderate	-----	-----	-----	Mode
PCBs	-----	Moderate	-----	-----	-----	-----	Mode
PENTACHLOROPHENOL	-----	Moderate	Moderate	-----	-----	-----	Mode
ETHYLENE DIBROMIDE	-----	Moderate	-----	-----	-----	-----	Mode

THM

Contaminant Name	Structural Integrity	Aquifer/Watershed Properties	Nonpoint Source	Point Source	Area Primary Influence	Contaminant Occurrence	Summary
BROMOCHLOROMETHANE	-----	Moderate	-----	-----	-----	-----	Mode
BROMODICHLOROMETHANE	-----	Moderate	-----	-----	-----	-----	Mode

BROMOFORM	----	Moderate	----	----	----	----	Mode
DIBROMOCHLOROMETHANE	----	Moderate	----	----	----	----	Mode

VOC - OTHER COMPOUNDS

Contaminant Name	Structural Integrity	Aquifer/Watershed Properties	Nonpoint Source	Point Source	Area Primary Influence	Contaminant Occurrence	Summary
2-HEXANONE	----	Moderate	----	----	----	----	Moderate
4-METHYL-2-PENTANONE (MIBK)	----	Moderate	----	----	----	----	Moderate
ACETONE	----	Moderate	----	----	----	----	Moderate
ACRYLONITRILE	----	Moderate	----	----	----	----	Moderate
METHYL ETHYL KETONE	----	Moderate	----	----	----	----	Moderate
METHYL METHACRYLATE	----	Moderate	----	----	----	----	Moderate
METHYL-T-BUTYL ETHER	----	Moderate	Moderate	----	----	----	Moderate
TETRAHYDROFURAN	----	Moderate	----	----	----	----	Moderate
VINYL ACETATE	----	Moderate	----	----	----	----	Moderate
ETHYL METHACRYLATE	----	Moderate	----	----	----	----	Moderate

VOC MONITORED

Contaminant Name	Structural Integrity	Aquifer/Watershed Properties	Nonpoint Source	Point Source	Area Primary Influence	Contaminant Occurrence	Summary
1,1,1,2-TETRACHLOROETHANE	----	Moderate	----	----	----	----	Moderate
1,1-DICHLOROETHANE	----	Moderate	----	----	----	----	Moderate
1,1-DICHLOROPROPENE	----	Moderate	----	----	----	----	Moderate
1,2,3-TRICHLOROBENZENE	----	Moderate	----	----	----	----	Moderate
1,2,3-TRICHLOROPROPANE	----	Moderate	----	----	----	----	Moderate
1,2,4-TRIMETHYLBENZENE	----	Moderate	----	----	----	----	Moderate
1,3,5-TRIMETHYLBENZENE	----	Moderate	----	----	----	----	Moderate
1,3-DICHLOROBENZENE	----	Moderate	Moderate	----	----	----	Moderate
2,2-DICHLOROPROPANE	----	Moderate	----	----	----	----	Moderate
4-CHLOROTOLUENE	----	Moderate	----	----	----	----	Moderate
4-ISOPROPYLTOLUENE	----	Moderate	----	----	----	----	Moderate
M + P XYLENE	----	Moderate	----	----	----	----	Moderate
NAPHTHALENE	----	Moderate	----	----	----	----	Moderate
N-BUTYLBENZENE	----	Moderate	----	----	----	----	Moderate
N-PROPYLBENZENE	----	Moderate	----	----	----	----	Moderate
BROMOBENZENE	----	Moderate	----	----	----	----	Moderate
S-BUTYLBENZENE	----	Moderate	----	----	----	----	Moderate
T-BUTYLBENZENE	----	Moderate	----	----	----	----	Moderate
CHLOROMETHANE	----	Moderate	----	----	----	----	Moderate
DIBROMOMETHANE	----	Moderate	----	----	----	----	Moderate
HEXACHLOROBUTADIENE	----	Moderate	----	----	----	----	Moderate
ISOPROPYLBENZENE	----	Moderate	----	----	----	----	Moderate

VOC REGULATED

Contaminant Name
Structural Integrity

Aquifer/Watershed Properties	Nonpoint Source	Point Source	Area Primary Influence	Contaminant Occurrence	Summary
MONOCHLOROBENZENE (CHLOROBENZENE)	Moderate	----	----	----	Moderate
M-XYLENE	Moderate	----	----	----	Moderate
BENZENE	Moderate	Moderate	----	----	Moderate
O-XYLENE	Moderate	----	----	----	Moderate
P-XYLENE	Moderate	----	----	----	Moderate
STYRENE	Moderate	----	----	----	Moderate

TRANS-1,2-DICHLOROETHYLENE	----	Moderate	Moderate	----	----	----	Moderate
VINYL CHLORIDE	----	Moderate	Moderate	----	----	----	Moderate
CIS-1,2-DICHLOROETHYLENE	----	Moderate	Moderate	----	----	----	Moderate
DICHLOROMETHANE	----	Moderate	Moderate	----	----	----	Moderate

Other

	Contaminant Name	Structural Integrity	Aquifer/Watershed Properties	Nonpoint Source	Point Source	Area Primary Influence	Contaminant Occurrence	Summary
RADIUM	P-ALKALINITY	----	Moderate	----	----	----	----	Moderate
	TOTAL ALPHA EMITTING	----	Moderate	----	----	----	----	Moderate
	TOTAL COLIFORM	----	Moderate	Moderate	----	----	----	Moderate
	TOTAL TRIHALOMETHANE	----	Moderate	----	----	----	----	Moderate
	CRYPTOSPORIDIUM PARVUM	----	Moderate	Moderate	----	----	----	Moderate
	ESCHERICHIA COLI	----	Moderate	Moderate	----	----	----	Moderate
	FECAL VIRUSES	----	Moderate	Moderate	----	----	----	Moderate
	GIARDIA LAMBLIA	----	Moderate	Moderate	----	----	----	Moderate

No contaminants with high susceptibility.

Contaminants with MODERATE Susceptibility

Contaminant List

List of regulated and unregulated assessed contaminants grouped by contaminant class. TCEQ Chapter 290 Subchapter F rules are cited for each drinking water standard (secondary drinking water standards are italicized). The TCEQ threshold limit is the concentration used within the contaminant occurrence component to determine if a detection of the chemical was found during water quality monitoring activities. The chemical abstract service (CAS) number is a unique identifier for each chemical.

D.W. CONTAM. CANDIDATE LIST

Contaminant Name	Drinking Water Standard	PWS Rule	TCEQ Threshold	CAS Number
CYANAZINE			0.01 ug/L	21725-46-2
DCPA DI-ACID DEGRADATE			0.00 ug/L	2136-79-0
BORON	2.20 mg/L		10.00 ug/L	11113-50-1
2,4,6-TRICHLOROPHENOL	0.08 mg/L		20.00 ug/L	88-06-2
2,4-DICHLOROPHENOL	0.07 mg/L		20.00 ug/L	120-83-2
2,4-DINITROPHENOL	0.05 mg/L		20.00 ug/L	51-28-5
2,4-DINITROTOLUENE	0.00 mg/L		5.00 ug/L	121-14-2
2,6-DINITROTOLUENE	0.00 mg/L		5.00 ug/L	606-20-2
2-METHYLPHENOL	0.05 mg/L		5.00 ug/L	95-48-7
ACETOCHLOR			0.01 ug/L	34256-82-1
1,2-DIPHENYLHYDRAZINE	0.00 mg/L		0.10 ug/L	122-66-7
1,3-DICHLOROPROPENE	0.01 mg/L		0.10 ug/L	542-75-6
PROPAZINE			0.01 ug/L	139-40-2
RDX	0.01 mg/L		0.10 ug/L	121-82-4
TERBACIL			0.01 ug/L	5902-51-2
TERBUFOS			0.01 ug/L	13071-79-9
DCPA MONO-ACID DEGRADATE			0.00 ug/L	887-54-7
DDE	0.00 mg/L		0.01 ug/L	72-55-9
DIAZINON	0.02 mg/L		0.01 ug/L	333-41-5
DISULFOTON	0.00 mg/L		0.01 ug/L	298-04-4
DIURON	0.05 mg/L		0.05 ug/L	330-54-1
EPTC	0.61 mg/L		0.01 ug/L	759-94-4
FONOFOS			0.01 ug/L	944-22-9
LINURON			0.01 ug/L	330-55-2
MOLINATE	0.05 mg/L		0.01 ug/L	2212-67-1
NITROBENZENE	0.01 mg/L		0.10 ug/L	98-95-3
ORGANOTINS				
PERCHLORATE				14797-73-0

INORGANICS

Contaminant Name	Drinking Water Standard	PWS Rule	TCEQ Threshold	CAS Number
CHLORIDE		\$290.113	125.00 mg/L	16887-00-6
CHROMIUM	0.10 mg/L	\$290.103(1)	50.00 ug/L	11104-59-9
COPPER	1.30 mg/L	\$290.120	65.00 ug/L	17493-86-6

	CYANIDE	0.20 mg/L	\$290.103(1)	0.01 mg/L	57-12-5
	BERYLLIUM	0.00 mg/L	\$290.103(1)	2.00 ug/L	14701-08-7
	BROMIDE				
	CADMIUM	0.01 mg/L	\$290.103(1)	2.50 ug/L	22537-48-0
	ALUMINUM	24.44 mg/L	\$290.113	0.10 ug/L	14903-36-7
	ANTIMONY	0.01 mg/L	\$290.103(1)	3.00 ug/L	64924-52-3
	ARSENIC	0.05 mg/L	\$290.103(1)	10.00 ug/L	15584-04-0
	ASBESTOS	7.00 mg/L		-9,999.00 ug/L	1332-21-4
	BARIUM	2.00 mg/L	\$290.103(1)	1,000.00 ug/L	16541-35-8
	SELENIUM	0.05 mg/L	\$290.103(1)	25.00 ug/L	7782-49-2
	SILVER	0.12 mg/L	\$290.113	25.00 ug/L	14701-21-4
	SULFATE	500.00 mg/L	\$290.113	125.00 mg/L	14808-79-8
	TDS		\$290.113	250.00 mg/L	
	THALLIUM	0.00 mg/L	\$290.103(1)	1.00 ug/L	7440-28-0
	ZINC	7.33 mg/L	\$290.113	2.50 ug/L	15176-26-8
	FLUORIDE	4.00 mg/L	\$290.103(1)	2.00 mg/L	16984-48-8
	HYDROGEN SULFIDE		\$290.113	0.00 mg/L	15035-72-0
IRON			\$290.113	150.00 ug/L	15438-31-0
	LEAD	0.02 mg/L	\$290.120	0.00 ug/L	14701-27
	ANGANESE	1.15 mg/L	\$290.113	25.00 ug/L	14333-14-3
MERCURY		0.00 mg/L	\$290.103(1)	1.00 ug/L	14302-87-5
NICKEL		0.49 mg/L	\$290.103(1)	50.00 ug/L	14701-22-5
	NITRATE TRATE+NITRITE	10.00 mg/L	\$290.103(1)	3.00 mg/L	14797-55-8
		10.00 mg/L	\$290.103(1)	3.00 mg/L	none
	NITRITE	1.00 mg/L	\$290.103(1)	0.50 mg/L	14797-65

M

NI

INORGANICS MONITORED

Contaminant Name	Drinking Water Standard	PWS Rule	TCEQ Threshold	CAS Numb
CARBONATE			1.00 mg/L	3812-32
BICARBONATE ALKALINITY			1.00 mg/L	71-52-3
SPECIFIC CONDUCTANCE			1.00 mg/L	14581-92-1
MAGNESIUM			1.00 uS/cm	
			0.01 mg/L	

INORGANICS UNREGULATED

Contaminant Name	Drinking Water Standard	PWS Rule	TCEQ Threshold	CAS Numb
CALCIUM			0.02 mg/L	14102-48
SODIUM			0.20 mg/L	17341-25

PHYSICAL

Contaminant Name	Drinking Water Standard	PWS Rule	TCEQ Threshold	CAS Number
HARDNESS			1.00 mg/L	

PHYSICAL PARAMETER

Contaminant Name	Drinking Water Standard	PWS Rule	TCEQ Threshold	CAS Number
pH		\$290.113	0.10 pH	

RADIOCHEM

Contaminant Name	Drinking Water Standard	PWS Rule	TCEQ Threshold	CAS Numb
RADIUM-226	5.00 mg/L	\$290.110	1.00 pCi/L	13982-63
RADIUM-228	5.00 mg/L	\$290.110	0.50 pCi/L	15262-20
STRONTIUM-90		\$290.110	0.50 pCi/L	10098-97
TRITIUM		\$290.110	1.00 pCi/L	15086-10
GROSS ALPHA	15.00 mg/L	\$290.110	3.00 pCi/L	
GROSS BETA	4.00 mg/L	\$290.110	3.00 pCi/L	

RADIOCHEM UNREGULATED

Contaminant Name	Drinking Water Standard	PWS Rule	TCEQ Threshold	CAS Numb
RADON	300.00 mg/L		0.50 pCi/L	10043-92

STRONTIUM-89 URANIUM

0.02 mg/L

0.50 pCi/L
1.00 ug/L14701-18-9
none

SOC MONITORED

Contaminant Name		Drinking Water Standard	PWS Rule	TCEQ Threshold	CAS Number
PHENANTHRENE	CHRYSENE	0.13 mg/L		0.10 ug/L	218-01-9
	BENZO[B]FLUORANTHENE	0.00 mg/L		10.00 ug/L	205-99-2
	BENZO[G,H,I]PERYLENE	0.73 mg/L		10.00 ug/L	191-24-2
	BENZO[K]FLUORANTHENE	0.01 ug/L		10.00 ug/L	207-08-9
	BROMACIL			0.05 ug/L	314-40-9
	BUTACHLOR			0.05 ug/L	23184-66-9
	BUTYL BENZYL PHTHALATE	4.89 mg/L		5.00 ug/L	85-68-7
	CARBARYL	2.44 mg/L		0.01 ug/L	63-25-2
	2,4,5-T	0.24 mg/L		0.05 ug/L	93-76-5
	3-HYDROXYCARBOFURAN ACENAPHTHENE	1.47 mg/L		0.05 ug/L	16655-82-6
ACENAPHTHYLENE ALDRIN				5.00 ug/L	83-32-9
		1.47 mg/L		5.00	208-96-8
		0.00 mg/L		ug/L	309-00-2
				0.10 ug/L	
	ANTHRACENE BENTAZON	7.33 mg/L		5.00	120-12-7
				ug/L	25057-89-0
				0.05 ug/L	
	BENZO[A]ANTHRACENE	0.00 mg/L		10.00 ug/L	56-55-3
				5.00 ug/L	85-01-8
	PROMETON PROPACHLOR			0.01 ug/L	1610-18-0
PYRENE TRIFLURALIN				0.01 ug/L	1918-16-7
		0.73 mg/L		0.10	129-00-0
		0.12 mg/L		ug/L	1582-09-8
				0.01 ug/L	
	DIBENZ[A,H]ANTHRACENE DICAMBA	0.00 mg/L		10.00 ug/L	53-70-3
		0.73 mg/L		0.05 ug/L	1918-00-9
	DIELDRIN DIETHYL PHTHALATE	0.00 mg/L		0.01	60-57-1
		19.55 mg/L		ug/L	84-66-2
				5.00 ug/L	
	DIMETHYL PHTHALATE DI-N-BUTYL	19.55 mg/L		5.00	131-11-3
PHTHALATE		2.44 mg/L		ug/L	84-74-2
				5.00 ug/L	
	FLUORENE INDENO[1,2,3,CD]PYRENE	0.98 mg/L		0.10 ug/L	86-73-7
				10.00 ug/L	193-39-5
	LAMBAST METHIOCARB			0.05	845-52-3
				ug/L	2032-65-7
				0.05 ug/L	
	METHOMYL METOLACHLOR	0.61 mg/L		0.05	16752-77-5
		3.67 mg/L		ug/L	51218-45-2
				0.01 ug/L	
METRIBUZIN				0.01	21087-64-9
				ug/L	

SOC REGULATED

Contaminant Name	Drinking Water Standard	PWS Rule	TCEQ Threshold	CAS Number
CHLORDANE	0 mg/L	0.0	0.10 ug/L	57-74-9
CHLORDANE (ALPHA-CHLORDANE)	0 mg/L	0.0	0.10 ug/L	5103-71-9
CHLORDANE (GAMMA-CHLORDANE)	0 mg/L	0.0	0.10 ug/L	12789-03-6
CHLORDANE (TRANS-NONACHLOR)	0 mg/L	0.0	0.10 ug/L	39765-80-5
DALAPON	0 mg/L	0.2	0.05 mg/L	75-99-0

	CARBOFURAN		0.0	\$290.103(3)(A)	0.01 ug/L	1563-66-2
	2,3,7,8-TCDD	4 mg/L	0.0	\$290.103(3)(A)	0.10	1746-01-6
	2,4,5-TP	0 mg/L	0.0	\$290.103(3)(A)	mg/L	93-72-1
	2,4-D	5 mg/L	0.0	\$290.103(3)(A)	0.05 ug/L	94-75-7
	ALACHLOR	7 mg/L	0.0	\$290.103(3)(A)	0.15 ug/L	15972-60-8
	ALDICARB	0 mg/L	0.0	\$290.103(3)(A)	0.01 ug/L	116-06-3
	ALDICARB	1 mg/L	0.0	\$290.103(3)(A)	0.55 ug/L	1646-88-4
	ALDICARB SULFONE	1 mg/L	0.0	\$290.103(3)(A)	0.10 ug/L	1646-87-3
	ALDICARB SULFOXIDE	1 mg/L	0.0	\$290.103(3)(A)	0.05 ug/L	1912-24-9
	ATRAZINE	0 mg/L	0.0	\$290.103(3)(A)	0.01 ug/L	50-32-8
	BENZO(A)PYRENE	0 mg/L	0.0	\$290.103(3)(A)	10.00	1918-02-1
	PICLORAM	0 mg/L	0.5	\$290.103(3)(A)	ug/L	122-34-9
	SIMAZINE	0 mg/L	0.0		0.01 ug/L	8001-35-2
	TOXAPHENE	0 mg/L	0.0	\$290.103(3)(A)	2.00 ug/L	103-23-1
ETHYLHEXYL)ADIPATE	DI-(2-	0 mg/L	0.4	\$290.103(3)(A)	5.00 ug/L	117-81-7
ETHYLHEXYL)PHTHALATE	DI-(2-	1 mg/L	0.0	\$290.103(3)(A)	5.00 ug/L	67708-83-2
NE	DIBROMOCHLOROPROPA	0 mg/L	0.0	\$290.103(3)(A)	0.10 ug/L	88-85-7
	DINOSEB	1 mg/L	0.0	\$290.103(3)(A)	0.05 ug/L	2764-72-9
	DIQUAT	2 mg/L	0.0	\$290.103(3)(A)	0.05	145-73-3
	ENDOTHALL	0 mg/L	0.1	\$290.103(3)(A)	mg/L	72-20-8
	ENDRIN	0 mg/L	0.0	\$290.103(3)(A)	0.05 ug/L	106-93-4
	ETHYLENE DIBROMIDE	0 mg/L	0.0	\$290.103(3)(A)	0.10 ug/L	1071-83-6
	GLYPHOSATE	0 mg/L	0.7	\$290.103(3)(A)	0.05 ug/L	76-44-8
	HEPTACHLOR	0 mg/L	0.0	\$290.103(3)(A)	0.10 ug/L	1024-57-3
	HEPTACHLOR EPOXIDE	0 mg/L	0.0	\$290.103(3)(A)	0.10 ug/L	118-74-1
	HEXACHLOROBENZENE	0 mg/L	0.0	\$290.103(3)(A)	5.00 ug/L	77-47-4
	HEXACHLOROCYCLOPENTADIENE	5 mg/L	0.0	\$290.103(3)(A)	5.00 ug/L	58-89-9
	LINDANE	0 mg/L	0.0	\$290.103(3)(A)	0.01 ug/L	72-43-5
	METHOXYCHLOR		0.0	\$290.103(3)(A)	0.05	23135-22-0
	OXAMYL PCBs	4 mg/L		\$290.103(3)(A)	ug/L	53469-21-9
		0.20 mg/L		\$290.103(3)(A)	0.05 ug/L	
		0.00 mg/L			0.10 ug/L	
	PENTACHLOROPHENOL		0.0	\$290.103(3)(A)	30.00 ug/L	87-86-5
		0 mg/L				

TH

M

Contaminant Name	Drinking Water Standard	PWS Rule	TCEQ Threshold	CAS Number
CHLOROFORM	0.10 mg/L	\$290.116	0.10	67-66-3
BROMOCHLOROMETHANE	0.98 mg/L		ug/L	74-97-5
BROMODICHLOROMETHANE	0.10 mg/L	\$290.116	ug/L	75-27-4
BROMOFORM	0.10 mg/L	\$290.116	ug/L	75-25-2
BROMOMETHANE	0.03 mg/L		ug/L	74-83-9

DIBROMOCHLOROMETHANE	0.10 mg/L	\$290.116	0.10 ug/L	124-48-1
----------------------	-----------	-----------	-----------	----------

VOC - OTHER COMPOUNDS

	Contaminant Name	Drinking Water Standard	PWS Rule	TCEQ Threshold	CAS Number
(MIBK)	CARBON DISULFIDE	2.44		0.10 ug/L	75-15-0
	2-HEXANONE	1.47		0.10 ug/L	591-78-6
	4-METHYL-2-PENTANONE	1.96		0.10 ug/L	108-10-1
	ACETONE	2.44		0.10 ug/L	67-64-1
	ACRYLONITRILE	0.00		0.10 ug/L	107-13-1
	TETRAHYDROFURAN	0.12		0.10 ug/L	109-99-9
	VINYL ACETATE	24.44		0.10 ug/L	108-05-4
(Iodomethane)	ETHYL METHACRYLATE	2.20		0.10 ug/L	97-63-2
	METHYL IODIDE	0.03		0.10 ug/L	74-88-4
	METHYL ETHYL KETONE	14.67		0.10 ug/L	78-93-3
	METHYL METHACRYLATE	34.22		0.10 ug/L	80-62-6
	METHYL-T-BUTYL ETHER	0.24		0.10 ug/L	1634-04-4

VOC MONITORED

	Contaminant Name	Drinking Water Standard	PWS Rule	TCEQ Threshold	CAS Number
E	CHLOROETHANE	9.78 mg/L		0.10 ug/L	75-00-3
	CHLOROMETHANE	0.07 mg/L		0.10 ug/L	74-87-3
	CIS-1,3-DICHLOROPROPENE	0.00 mg/L		0.10 ug/L	10061-01-5
	BROMOBENZENE	0.49 mg/L		0.10 ug/L	108-86-1
	2-CHLOROTOLUENE	0.49 mg/L		0.10 ug/L	95-49-8
	4-CHLOROTOLUENE	0.49 mg/L		0.10 ug/L	106-43-4
	4-ISOPROPYLTOLUENE	2.44 mg/L		0.10 ug/L	99-87-6
	1,1,1,2-TETRACHLOROETHANE	0.04 mg/L		0.10 ug/L	630-20-6
	1,1,2,2-TETRACHLOROETHANE	0.17 mg/L		0.10 ug/L	79-34-5
	1,1-DICHLOROETHANE	2.44 mg/L		0.10 ug/L	75-34-3
	1,1-DICHLOROPROPENE	0.01 mg/L		0.10 ug/L	563-58-6
	1,2,3-TRICHLOROBENZENE	0.07 mg/L		0.10 ug/L	87-61-6
	1,2,3-TRICHLOROPROPANE	0.00 mg/L		0.10 ug/L	96-18-4
	1,2,4-TRIMETHYLBENZENE	1.22 mg/L		0.10 ug/L	95-63-6
	1,3,5-TRIMETHYLBENZENE	1.22 mg/L		0.10 ug/L	108-67-8
	1,3-DICHLOROBENZENE	0.73 mg/L		0.10 ug/L	541-73-1
	1,3-DICHLOROPROPANE	0.01 mg/L		0.10 ug/L	142-28-9
	2,2-DICHLOROPROPANE			0.10 ug/L	594-20-7
	S-BUTYLBENZENE	0.98 mg/L		0.10 ug/L	135-98-8
	T-BUTYLBENZENE	0.98 mg/L		0.10 ug/L	98-06-6
	TRANS-1,3-DICHLOROPROPENE	0.01 mg/L		0.10 ug/L	10061-02-6
	TRICHLOROFLUOROMETHANE	7.33 mg/L		0.10 ug/L	75-69-4
	DIBROMOMETHANE	0.12 mg/L		0.10 ug/L	74-95-3
	DICHLORODIFLUOROMETHAN	4.89 mg/L		0.10 ug/L	75-71-8
	HEXACHLOROBUTADIENE	0.00		0.10 ug/L	87-68-3
	ISOPROPYLBENZENE	2.44 mg/L		0.10 ug/L	98-82-8
	M + P XYLENE				0.10 ug/L

	NAPHTHALENE	0.49 mg/L		0.10	91-20-3
			ug/L		
	N-BUTYLBENZENE	0.98 mg/L		0.10	104-51-8
N-PROPYLBENZENE	0.98 mg/L		ug/L	103-65-1	
			0.10 ug/L		

VOC REGULATED

Contaminant Name		Drinking Water Standard	PWS Rule	TCEQ Threshold	CAS Number
CHLOROBENZENE		0.10		0.10	108-
(MONOCHLORBENZENE)	mg/L			ug/L	90-7
CIS-1,2-DICHLOROETHYLENE		0.07	\$290.103(3)(B)	0.10	156-
	mg/L			ug/L	59-2
CARBON TETRACHLORIDE		0.00	\$290.103(3)(B)	0.10	56-
	mg/L			ug/L	23-5
1,1,1-TRICHLOROETHANE		0.20	\$290.103(3)(B)	0.10	71-
	mg/L			ug/L	55-6
1,1,2-TRICHLOROETHANE		0.01	\$290.103(3)(B)	0.10	79-
	mg/L			ug/L	00-5
1,1-DICHLOROETHYLENE		0.01	\$290.103(3)(B)	0.10	75-
	mg/L			ug/L	35-4
1,2,4-TRICHLOROBENZENE		0.07	\$290.103(3)(B)	0.10	120-
	mg/L			ug/L	82-1
1,2-DICHLOROETHANE		0.01	\$290.103(3)(B)	0.10	107-
	mg/L			ug/L	06-2
1,2-DICHLOROPROPANE		0.01	\$290.103(3)(B)	0.10	78-
	mg/L			ug/L	87-5
BENZENE		0.01	\$290.103(3)(B)	0.10	71-
	mg/L			ug/L	43-2
P-XYLENE			\$290.103(3)(B)	0.10	106-
				ug/L	42-3
STYRENE		0.10	\$290.103(3)(B)	0.10	100-
	mg/L			ug/L	42-5
TETRACHLOROETHYLENE		0.01	\$290.103(3)(B)	0.10	127-
	mg/L			ug/L	18-4
TOLUENE		1.00	\$290.103(3)(B)	0.10	108-
	mg/L			ug/L	88-3
TRANS-1,2-DICHLOROETHYLENE		0.10	\$290.103(3)(B)	0.10	156-
	mg/L			ug/L	60-5
TRICHLOROETHYLENE		0.01	\$290.103(3)(B)	0.10	79-
	mg/L			ug/L	01-6
VINYL CHLORIDE		0.00	\$290.103(3)(B)	0.10	75-
	mg/L			ug/L	01-4
XYLENES (TOTAL)		10.00	\$290.103(3)(B)	0.10	non
	mg/L			ug/L	e
DICHLOROMETHANE		0.01	\$290.103(3)(B)	0.10	75-
	mg/L			ug/L	09-2
ETHYLBENZENE		0.70	\$290.103(3)(B)	0.10	100-
	mg/L			ug/L	41-4
MONOCHLOROBENZENE			\$290.103(3)(B)	0.10	108-
(CHLOROBENZENE)				ug/L	90-7
M-XYLENE		10.00		0.10	108-
	mg/L			mg/L	38-3
ORTHO-1,2-DICHLOROBENZENE		0.60	\$290.103(3)(B)	0.10	95-
	mg/L			ug/L	50-1
O-XYLENE			\$290.103(3)(B)	0.10	95-
				mg/L	47-6
PARA-1,4-DICHLOROBENZENE		0.08	\$290.103(3)(B)	0.10	106-
	mg/L			ug/L	46-7

Other

Contaminant Name	Drinking Water Standard	PWS Rule	TCEQ Threshold	CAS Number
CRYPTOSPORIDIUM PARVUM				
AROCLOR (PCB)			0.05 ug/L	53469-21-9
TOTAL ALPHA EMITTING RADIUM	5.00	\$290.11		
	mg/L	0		
TOTAL COLIFORM				
TOTAL TRIHALOMETHANE	0.10	\$290.11	0.10 ug/L	
	mg/L	6		
TRIAZINES				

ESCHERICHIA COLI
FECAL VIRUSES
GIARDIA LAMBLIA
P-ALKALINITY